



# Specification & Design Considerations for Sewer Bypass

**Tony de Bellis / Garrett Rehs**

June 2024

# Agenda

---

- INTRODUCTION
- OVERVIEW OF RAIN FOR RENT & PROJECTS
- SPEC WRITING CONSIDERATIONS
- BYPASS PROJECT PITFALLS
- DESIGN PREFERENCE IMPACTS ON COST
- TWO CASE STUDIES



# First – Thank you!

---

- We Know That Putting Together These Projects – In Writing And For The Record! Not Easy
- Consider Us A Resource. Call Anytime.
  - *This Is Just Our Experience*
- This Is Focused On Raw Sewer Bypass But Does Apply To Water And 2<sup>nd</sup> Effluent



# Family-Owned for 90 Years

---



**Liquid Ingenuity**<sup>®</sup>  
Since 1934




# Company Owned Local Operations

---

We Are Family-owned Business Backed By

61 Branches • 90 Years Of Experience • Centralized Engineering Department



# How We Help Our Customers

## *Temporary Liquid Handling Solutions*

### **COMPLEX**

Managing Liquid  
Handling Risk.

High Performance.

On-site Project  
Management.

Engineering And  
Ingenuity.

Problems Solved  
Correctly. The First Time.



### **ROUTINE**

Quality Equipment.

Availability.

Local Service.

24/7 Call-out.

Reliability.

Project Guidance.

Execution And  
Efficiency.

**Responsive | Safe | Proven Expertise**




# Our Goal



*Helping you achieve your project objectives without having to worry about how to handle liquids.*



# Design Services



LAYOUT

DENVER METRO WWTP  
BROWN & CALDWELL

Rain For Rent  
Engineering

3940 E. 10TH AVE., P.O. BOX 1248, DENVER, CO 80202

NO. 1	REV.	DATE	BY	CHKD	APP'D	DESC
1						

112075

JOB NO. 1081326

# Design Services



*Phoenix Bypass*  
145 MGD



*Memphis Bypass*  
120 MGD



# Design Services

*Sydney Tar Ponds, Nova Scotia 9*  
**354 MGD**



# 576 MGD Flood Control

- Omaha, Nebraska
- Combined Sewer Overflow During Rain Events
- Unique Floating Pumps Capable Of ~100MGD Each
- Dv600c's (5), Electric And Hydraulic Submersibles



# Plant Sewer Bypass



# Cooling Tower Bypass/Filter



# Cooling Tower Bypass



# Potable Water Emergency Pumping



# 125 CFS Canal Bypass – Knightsen, CA



# What Is A Bypass, Really?

---

- A Temporary Lift Station That Must Be As Reliable As A Permanent Lift Station
- Both Can Be Quite Expensive
- Would You Risk Under Sizing Or Oversizing Your Permanent Lift Station?



# Specification Writing


---

- Bypass Projects Have A Clear Risk Vs. Cost Relationship
- Not All Bypasses Have The Same Risk Parameters
- Goal Of The Spec:
  - Give The Contractor Enough Detail With Clear Requirements So That The System Installed Matches The Risk Comfort Levels & Estimated Budget.
  - Contractors also manage risk. A good spec. will bring more competition to the bid.




# Cost vs. Risk

---



# Cost vs. Risk

WHERE IS YOUR PROJECT?



# Mistakes We Have Seen (*recently*)

---

- Safety Factor Applied To Flow Not Redundancy – Actual Was 17 MGD Spec Said 25 MGD (Oversize x 1.5)
- Pump Redundancy Requirement Called Out For The Average Flow Not The Peak Flow (Undersize)
- Spec Flow 30% Of Actual Flow (Undersize)
- Suction Lift Required Violates Laws Of Physics
- Impractical daily bypass set-up and tear down requirement



# What We Need In The Spec

---


- Correct High Flow And Low Flow – Average Is Irrelevant
- Elevations (Suction Lift)(Surcharge Limits)
- Withdrawal Location
- Discharge Location
- Required Redundancy For High Flow
- Required Material (Hint – HDPE Is Lowest Risk)
- Pump & Pipeline Protection (K-rail?)



# What You Can Have In The Spec.

---

- Contractor Experience Requirements.
- Automation Or Instrument Requirements.
- Pipeline Velocity's.
- Vertically Integrated Services And Equipment.
- Bypass Test/Commissioning Period (72 Hrs.)
- Bypass providers pre-qualification to bid.



# Accurate Flow Rates

---

- Modeling Accuracy Depends On Accuracy Of Inputs
  - Downstream Debris Changes Fullness
  - Ground Water Seepage
  - Unknown Laterals
  - Corrosion/Roughness Of Pipeline
  - Storm Run-off
  - Have Faith In Our Ancestor Engineers! That 50 y/o 18" pipe is there for a reason.
- Our Experience – Flows From Models Need To Be Fact Checked By Opening The Manhole Or Installing Temp Flow Meters.



# Accurate Flow Rates

---

- Inaccurate Inputs → Inaccurate Flows → Over/Under Designed Bypass System
- Which Is More Money And Delays & Opportunity Cost To The Owner
- If Possible, Verify Model Inputs & Output With:
  - Flow Meters (Temporary Or Existing)
  - Hazen Williams Equation – Slope / Fullness / Roughness



# Plans & As-Built's

---

- Historical Drawings
  - May Not Show Upgrades, Modifications, Or Other Changes To The System



# Omaha, NE 576MGD Station

---


CULVERT X-SECTION AS  
SHOWN ON PLANS  
(30" CONCRETE WALLS)



# Omaha, NE 576MGD Station

---


The Plan...Concrete Cut Lid and Place  
Floating Pump Inside Culvert



# Omaha, NE 576MGD Station

---

Actual Culvert X-section With  
Weir Wall



# Solution



# Pump Station Design

- Centrifugal Vs. Submersible
- Redundancy & Pump Watch



# Pump Choice

---

- Centrifugal Pumps
  - Theoretical Suction Lift Of 28ft
  - Realistic Suction Lifts Of Up To 15 To 20 Ft
    - NPSHR Is Huge Towards Far Right Of Curve
  - Solids Handling Up To 4"
  - Open Or Semi-open Impeller
  - Easy To Swap Out
  - Self Priming (Can Have Backup Priming)
  - Requires 3-5ft Of Suction Submergence/Surge
  - Smaller Footprint In The Manhole/Pipeline

Example - 18" suction stinger for 3500GPM



# Lift vs. Flow

- 12" Pump w/ 12" suction and 500' feet 12" discharge 0 elevation change. Site elevation is 5'

Suction Lift (ft)	Flow Rate (GPM)	TDH (ft)
6	5500	72
12	5000	68
14	4500	60
16.5	4000	54
18	3500	48
19.5	3000	42
21	2500	38
22	2000	34
23	1500	31
23.5	1000	29
24	500	27



# Centrifugal Pumps



# Submersible Pumps

---

- Great For Deeper Vaults (21'+)
  - No Suction Lift – All Discharge
- Quite And Out Of The Way
- Difficult To Swap Out
- Require Generators Or Power Drop and VFD's
- Power can be separated from pump – smaller footprint
- Should Be Explosion Proof
- 3500 GPM Trash Sub = 44" At The Base



# Submersible Pump



# Redundancy Defined


---

- Please - Clearly Define Redundancy At Peak Flow
  - For Pumps And Generators
    - 100% 1 Backup Pump Per 1 Duty Pump
    - 50% 1 Backup Pump Per 2 Duty Pumps
  - For Discharge Pipe
    - 1 Main Capable Of Peak Flow = 0%
    - 2 Main Capable Of Peak Flow = 100%
- Its All About Risk (in the Public Right Of Way?)



# Single Discharge Line - Example

---



# Single Discharge Line - Example

---



# Pump Watch (Operators)

---

- Need To Define If On Site Manning Is Required Or You Will Get A Ring Camera.
- 2-man Crew Minimum (1 Person Is A Witness)
- 95% Boredom 5% Stark Terror. Owner Is Paying For The 5%.
- Automation Is Great – In Reality People Are Hours Away (DOT hours of service for example)
- Raw Sewer Bypass Needs Manning – Water Probably Not



# De-Ragging

---

- Even Non-clog Impellers Need Cleaning



# Final Pump Station Goal


*Nova Scotia 9*  
**354 MGD**



# Surface Ramp For Discharge

---

- Road Crossings
- Materials
- Connections
- Velocities



# Surface Ramp

---



# Discharge Road Crossings

---

- Trench And Plating Is Preferred Method
  - Should Trench And Plate For Pipelines Over 6" In Diameter
- Poor Alternative (Surface Ramps)
  - Slow Traffic / Traffic Hazard / Cars can high center.
  - Can Clog When Pumping Sewage / Good For Water.
  - Unstable On Roads
    - Crossings Are Flat
    - Roads Have A Crown For Drainage



# Discharge Material

---

- Various Materials With Wide Spectrum Of Pros and Cons
  - Fused High Density Polyethylene (HDPE)
    - Leak Proof/Car Proof/Bullet Proof (Not Truck Proof)
    - Readily Available From 2" To 36"
    - High Installation Costs
  - Layflat Hose/Rigid Hose
    - Quick Install
    - Pressures To At Least 75 Psi
    - 12" And Below
    - Hose Bauer and Camlock Connections Prone To Vandalism



# Discharge Material

---


- Various Materials With Wide Spectrum Of Pros and Cons
  - Aluminum Pipe
    - Quick Install W/Limited Labor
    - High Pressure Rating
    - Available 12" And Smaller
    - Horrible Suction Rating
    - Thin Walled / Brittle
    - High Scrap Value Is Tempting To Vandals
  - PVC
    - High Pressure Rating
    - Leak Proof
    - Becomes Brittle Over Time
    - Expensive (Labor & Material) For Large Diameters



# Connections

---

- Various Connection Types
  - Fusion Welded
  - Flanged
  - Industrial Groove (Victaulic)
  - Glued
  - Cam Lock
  - Bauer



# Discharge Velocities

---

- Typical Engineering Design Standards
  - Short Sections Of Steel Or HPDE Pipe
    - Up To 20 Ft/Sec
  - Typical Sewer Bypass Mainlines
    - Up To 12 Ft/Sec
  - Discharge Into Critical Or Fragile Structures
    - Up To 5 Ft/Sec
  - Dangers:
    - Water Hammer (pump control setup is important here)
    - Damage To Structures



# Specification Writing

---

- Submittal Requirements
  - Pe Stamped Calculations & Drawings
    - Proof Of Concept
    - Eliminates The “I Know It Will Work Because It Worked Last Time” Mentality
    - Eliminate Submittal Calcs From An iPhone App



# Submittal Calculations

## Lift and TDH calculations for the pumps listed below

- (4) DV-200c @ 2605 GPM / Pump Primary
- (2) DV-200c @ 2605 GPM / Pump Backup

PIPE	Suction	Discharge-1	Discharge-2
Type	Hose	Aluminum	HDPE
Dia (in)	12	12	18
Rating	Suction	Ind Grove	32.5
I.D. (in)	12	11.812	16.826
Length (ft)	30	100	1150
Flow (gpm)	2605	2605	5209
Velocity (ft/s)	7.391	7.628	7.517

## Total Suction Lift

14.60 Ft. lift, water==>ground level  
 0.35 Ft. Pipe Hf for 12" x 30' Suction Hose  
 0.66 Ft. Entrance Loss (k = 0.78)  
 0.33 Ft. (1) 12" 90° Elbow (k = 0.39)  
 1.13 Ft. 12" x 8" Priming Reducer (k = 0.64)  
 3.29 Ft. Trailer/ Skid Height  


---

 20.36 Ft.

## NPSH

Altitude (Ft):	100
Atm Pressure (Ft):	33.88
Vapor Loss @ 80°F (Ft):	1.20
NPSHA	12.32
NPSHR	8.00
NPSHA > NPSHR	<b>OK</b>

## Total Dynamic Head (TDH)

1.62 Ft. Pipe Hf loss 12" x 100' Ind Groove Al Pipe  
 6.01 Ft. 8" Check Valve (k = 1.4)  
 1.13 Ft. 8" x 12" Enlargement (k = 0.64)  
 2.61 Ft. (8) 12" Ind Groove 90° Elbow (k = 0.36)  
 0.08 Ft. (1) 12" Gate Valve (k = 0.10)  
 2.12 Ft. (1) 12" x 18" Manifold (k = 2.5)  
 0.07 Ft. (1) 18" Gate Valve (k = 0.10)  
 9.22 Ft. Pipe Hf loss 18" x 1150' HDPE SDR 32.5  
 1.03 Ft. (3) 18" HDPE SDR 17 90° Elbow (k = 0.39)  
 15.00 Ft. Elevation Increase  
 20.36 Ft. Suction Lift  



---

**59 Ft. Required Pump Pressure**  
**26 PSI**





# Submittal Drawing



**PUMP STATION DETAIL**  
**NOT TO SCALE**



# Pitfalls To Watch For

---

- Cone Removal
- Surcharging
- Clean Water Source
- Surging Flows Into Plant



# Manhole Cone Removal

---

- Typical Manhole Covers Are 22"-24"
  - Enough Room For (3) 8" Suction Hoses
- Should Remove Cone For Bypasses Above 5MGD
- May need to excavate and open the pipe.
- Extra Costs Excavating And Rehab
- Result –Possible Change Order Or
  - System Is Undersized
  - Suction Lines Are Undersized
  - Common Suctions Are Used
  - Pump System Is Not Optimal



# Cone Removed

---



# Surcharging

---

- “The More The Better...as Long As It Is Not Too Much!”
  - All Pumps Require Submergence To Operate Properly – Rule Of Thumb 3 To 5 X The Dia. Of Suction Hose
  - Vortex – loose prime – wait to re-prime. Minutes seem like hours
  - Suction stingers need separation
  - Surcharging Reduces Suction Lift Which Increases Submergence Which Increases Performance.
  - The joke is – surcharge is a self-correcting problem.
  - Caution:
    - Upstream Conditions
    - Suction Manhole/Wet Well Conditions (size)



# Too Much Surcharge



# On-site Water (Hydrant)

---

- Hydro-test Prior To System Startup
- Flush Prior To System Removal
- Clean Water Is Required For Both Operations
  - If Not Onsite And Available, Contractor Will Need To Truck In Water
  - Result Is Possible Change Order Or System Is Not Hydro-tested And Flushed Properly



# Surging Plant Flow

---

- Bypass Flows Should Mimic Natural Diurnal Incoming Flows
- Bypass Systems With On/Off Mechanical Floats Can Cause Surges Into The Plant
- Result:
  - Damage To Existing Infrastructure
  - Inaccurate Plant Flow Measurement
  - Damage To Digester Or Ras Bacteria
- Solution
  - Precision Level Holding Automation @
  - Telemetry



# Design Impacts On Cost

---

- Overestimate Of Flows
- Aluminum Vs HDPE Vs Hose
- Level Control Automation
- Pump Watch



# Overestimate Of Flows

---

- Pumps Tend To Be Linear To Flow Rates
  - 40MGD Pump Is 2.5x The Cost Of 20MGD Pump
- Install Labor & Pipeline Costs Are Not Linear
  - 40MGD Labor Is 4 X The Cost Of 20MGD
  - Larger Systems Require:
    - Forklifts
    - Cranes
    - Generators
    - Higher Material Costs
    - Longer Install Times
    - Cone Removal



# Aluminum Vs HDPE

---

- 400ft 12" Aluminum
  - Install Costs = \$2k
- 400ft 12" Fused HDPE
  - Install Costs = \$5k
- Reasons:
  - Forklift, Fusion Machine, Fuel, Heating & Cooling Times



# Pump / Level Control (2 pumps)

---

- Mechanical On/Off Floats
  - Hold Level To Within 5ft
  - Cost Of Install = \$500
  - Monthly Rental Cost = \$300
  - Surges and Short Cycle Pump Issues
- Speed Control Automation
  - Hold Level To Within 2"
  - Cost Of Install = \$5k
  - Monthly Rental Cost = \$5k
  - Smooth



# Pump Watch

---

- Recommended On Sewer Projects
- Ensures Onsite Personnel Are Instantly Available To Manage The Problems
- Expensive
- Typical Daily Cost For 2-man Crew
  - \$5 to \$7k Per 24 Hour Day
  - (2) 2-person Crews On 12-hr Shifts
  - Why? PW Weekend O/T And D/T



# Conclusion

---

- A Clear Spec And Scope Will Allow The Bypass Contractor To Provide The Customer With A System That Adheres To Their Risk Vs Cost Comfort Level
  - Owner Spends The Right Amount Of Money
  - Avoid Change Orders, Change Directives, Fines, Fees, Spills, Reputation Damage
  - Level Playing Field For Contractors
  - We Can All Sleep Better



# Case Study 1 – Bay Area

	<b>Specification Called called out</b>		<b>Actual Site Conditions</b>
<b>PDWF</b>	9 MGD		26 MGD 40 MGD spike
<b>Control</b>	Float Switch's		Automate multiple pumps w/ SCADA output
<b>Lift</b>	12'		16'
<b>Upstream</b>	Gravity flow		Large lift station
<b>Price</b>	<b>Bid price</b> \$850K		<b>Final Cost</b> \$4.2 M
<b>Project Delay</b>	N/A		1 year



# Case Study 1

---



# Case Study 2 – Bay Area

	Specification Called called out		Actual Site Conditions
PDWF	22 MGD		22 MGD
Control	Local automate		Local automate
Lift	Elevations not provided Bid Q "Can we surcharge?" Bid A "whatever is needed"		Desired 6' surcharge for 13' lift plant ops limited project 2' surcharge for 17' lift
upstream	Gravity Flow		Gravity Flow
Price	N/A		plus \$150K (extra pumps)
Project Delay	None		None



# Case Study 3 – Bay Area

	Specification Called		Actual Site
	out		Conditions
<b>PDWF</b>	25.5 MGD		25 MGD
<b>Control</b>	Automate multiple pumps w/ SCADA output Temp bar screen		Automate multiple pumps w/ SCADA output Temp bar screen
<b>Lift</b>	4'		4'
<b>Unstream</b>	Gravilty flow		distant lift sta.
<b>Price</b>	<b>Bid price</b> \$2.2 M		<b>Final Cost</b> \$2.2 M
<b>Project Delay</b>	none - great spec.		none - great spec.





**THANK YOU!  
ANY QUESTIONS?**

**Tony de Bellis**

925-679-2803